

ITEM 4.3.4 | ACCESSIBLE ROUTE - PASSING SPACE

If an accessible route has less than 60 in (1525 mm) clear width, then passing spaces at least 60 in by 60 in (1525 mm by 1525 mm) shall be located at reasonable intervals not to exceed 200 ft (61 m). A T-Intersection of two corridors or walks Is an acceptable passing place.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)

