

ITEM 4.4.2 | PROTRUDING OBJECTS - HEED ROOM

Walks, halls, corridors, passageways, aisles, or other circulation spaces shall have 80 in (2030 mm) minimum clear head room (see Fig. 8(a)). If vertical clearance of an area adjoining an accessible route is reduced to less than 80 in (nominal dimension), a barrier to warn blind or visually - Impaired persons shall be provided (see Fig. 8(c1)).

("1991 Standards for Accessible Design", 28 CFR 36 Appendix D)

