

ITEM 4.5.2 | GROUND AND FLOOR SURFACES - CHANGES IN LEVEL

Changes in level up to $\frac{1}{4}$ in (6 mm) may be vertical and without edge treatment (see Fig. 7(d)). Changes In level between $\frac{1}{4}$ in and $\frac{1}{2}$ in (6 mm and 13 mm) shall be beveled with a slope no greater than 1:2 (see Fig. 7(d)). Changes In level greater than $\frac{1}{2}$ in (13 mm) shall be accomplished by means of a ramp that complies with 4.7 or 4.8.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)

