

ITEM 4.8.4 | RAMPS - LANDINGS

Ramps shall have level landings at bottom and top of each ramp and each ramp run. Landings shall have the following features:

- (1) The landing shall be at least as wide as the ramp run leading to it.
- (2) The landing length shall be a minimum of 60 In (1525 mm) clear.
- (3) If ramps change direction at landings, the minimum landing size shall be 60 In by 60 In (1525 mm by 1525 mm).
- (4) If a doorway is located at a landing, then the area in front of the doorway shall comply with 4.13.6.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)