

ITEM 4.8.7 | RAMPS - EDGE PROTECTION

Ramps and landings with drop-offs shall have curbs, walls, railings, or projecting surfaces that prevent people from slipping off the ramp. Curbs shall be a minimum of 2 in (50 mm) high (see Fig. 17).

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)

