

ITEM 4.10.5 | ELEVATORS - RAISED AND BRAILLE CHARACTERS ON HOISTWAY ENTRANCES

All elevator hoistway entrances shall have raised and Braille floor designations provided on both jambs. The centerline of the characters shall be 60 in (1525 mm) above finish floor. Such characters shall be 2 in (50 mm) high and shall comply with 4.30.4. Permanently applied plates are acceptable if they are permanently fixed to the jambs. (See Fig. 20).

("1991 Standards for Accessible Design", 28 CFR 36 Appendix D)

