

ITEM 4.13.8 | DOORS - THRESHOLDS AT DOORWAYS

Thresholds at doorways shall not exceed 3/4 in (19 mm) in height for exterior sliding doors or ½ in (13 mm) for other types of doors. Raised thresholds and floor level changes at accessible doorways shall be beveled with a slope no greater than 1:2 (see 4.5.2).

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)

