

ITEM 4.16.4 | WATER CLOSETS - GRAB BARS

Grab bars for water closets not located in stalls shall comply with 4.26 and Fig. 29. The grab bar behind the water closet shall be 36 in (915 mm) minimum.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)

