

ITEM 4.16.5 | WATER CLOSETS - FLUSH CONTROLS

Flush controls shall be hand operated or automatic and shall comply with 4.27.4. Controls for flush valves shall be mounted on the wide side of toilet areas no more than 44 in (1120 mm) above the floor.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)

