

ITEM 4.17.4 | TOILET STALLS - TOE CLEARANCES

In standard stalls, the front partition and at least one side partition shall provide a toe clearance of at least 9 in (230 mm) above the floor. If the depth of the stall is greater than 60 in (1525 mm), then the toe clearance is not required.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)

