

ITEM 4.17.5 | TOILET STALLS - DOORS

Toilet stall doors, including door hardware, shall comply with 4.13. If toilet stall approach is from the latch side of the stall door, clearance between the door side of the stall and any obstruction may be reduced to a minimum of 42 in (1065 mm) (Fig. 30).

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)

