

ITEM 4.18.3 | URINALS - CLEAR FLOOR SPACE

A clear floor space 30 in by 48 in (760 mm by 1220 mm) shall be provided in front of urinals to allow forward approach. This clear space shall adjoin or overlap an accessible route and shall comply with 4.2.4. Urinal shields that do not extend beyond the front edge of the urinal rim may be provided with 29 in (735 mm) clearance between them.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)

