

ITEM 4.18.4 | URINALS - FLUSH CONTROLS

Flush controls shall be hand operated or automatic, and shall comply with 4.27.4. and shall be mounted no more than 44 in (1120 mm) above the finish floor.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)