

ITEM 4.19.6 | LAVATORIES AND MIRRORS - MIRRORS

Mirrors shall be mounted with the bottom edge of the reflecting surface no higher than 40 in (1015 mm) above the finish floor (see Fig. 31).

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)