

ITEM 4.22.3 | TOILET ROOMS - CLEAR FLOOR SPACE

The accessible fixtures and controls required in 4.22.4, 4.22.5, 4.22.6, and 4.22.7 shall be on an accessible route. An unobstructed turning space complying with 4.2.3 shall be provided within an accessible toilet room. The clear floor space at fixtures and controls, the accessible route, and the turning space may overlap.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)

