

ITEM 4.22.4 | TOILET ROOMS - WATER CLOSETS

If toilet stalls are provided, then at least one shall be a standard toilet stall complying with 4.17; where 6 or more stalls are provided. In addition to the stall complying with 4.17.3. at least one stall 36 in (915 mm) wide with an outward swinging, self-dosing door and parallel grab bars complying with Fig. 30(d) and 4.26 shall be provided. Water closets in such stalls shall comply with 4.16. If water closets are not in stalls, then at least one shall comply with 4.16.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)

