

**ITEM 4.23.9 | BATHROOMS, BATHING FACILITIES, AND SHOWER ROOMS -
MEDICINE CABINETS**

If medicine cabinets are provided, at least one shall be located with a usable shelf no higher than 44 in (1120 mm) above the floor space. The floor space shall comply with 4.2.4.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)

