

ITEM 4.28.1 | ALARMS - GENERAL

Alarm systems required to be accessible by 4.1 shall comply with 4.28. At a minimum, visual signal appliances shall be provided in buildings and facilities in each of the following areas: restrooms and any other general usage areas (e.g., meeting rooms), hallways, lobbies, and any other area for common use.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)

