

ITEM 4.28.2 | ALARMS - AUDIBLE ALARM*

If provided, audible emergency alarms shall produce a sound that exceeds the prevailing equivalent sound level in the room or space by at least 15 dbA or exceeds any maximum sound level with a duration of 60 seconds by 5 dbA, whichever is louder. Sound levels for alarm signals shall not exceed 120 dbA.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)

