

ITEM 4.28.4 | ALARMS - AUXILIARY ALARMS

Units and sleeping accommodations shall have a visual alarm connected to the building emergency alarm system or shall have a standard 110-volt electrical receptacle into which such an alarm can be connected and a means by which a signal from the building emergency alarm system can trigger such an auxiliary alarm. When visual alarms are in place the signal shall be visible in all areas of the unit or room. Instructions for use of the auxiliary alarm or receptacle shall be provided.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)

