

ITEM 9.3.1 | VISUAL ALARMS, NOTIFICATION DEVICES AND TELEPHONES - GENERAL

In sleeping rooms required to comply with this section, auxiliary visual alarms shall be provided and shall comply with 4.28.4. Visual notification devices shall also be provided in units, sleeping rooms and suites to alert room occupants of incoming telephone calls and a door knock or bell. Notification devices shall also be connected to auxiliary visual alarm signal appliances. Permanently installed telephones shall have volume controls complying with 4.31.5; an accessible electrical outlet within 4 ft (1220 mm) of a telephone connection shall be provided to facilitate the use of a text telephone.

("1991 Standards for Accessible Design", 28 CFR 36 Appendix D)