

ITEM 9.3.2 | VISUAL ALARMS, NOTIFICATION DEVICES AND TELEPHONES - EQUIVALENT FACILITATION

For purposes of this section, equivalent facilitation shall include the installation of electrical outlets (including outlets connected to a facility's central alarm system) and telephone wiring in sleeping rooms and suites to enable persons with hearing impairments to utilize portable visual alarms and communication devices provided by the operator of the facility.

("1991 Standards for Accessible Design", 28 CFR 36 Appendix D)

