



ADA ACCESSIBILITY GUIDELINES FOR BUILDINGS AND FACILITIES
CHAPTER 6: MEDICAL CARE FACILITIES
[ALL-IN-ONE DOCUMENT]

{7/26/1991}

E: TextBookDiscrimination@gmail.com
W: www.TextBookDiscrimination.com

visit TBD's [website](http://www.TextBookDiscrimination.com) for the most up-to-date information

TABLE OF CONTENTS | CHAPTER 6: MEDICAL CARE FACILITIES

#	Section	Title	Page
F001	6.1.0	General	4
F002	6.2.0	Entrances	6
F003	6.3.0	Patient Bedrooms	7
F004	6.4.0	Patient Toilet Rooms	8
-	n/a	Outro	9



ADA ACCESSIBILITY GUIDELINES
FOR BUILDING AND FACILITIES

CHAPTER: 6

TITLE: MEDICAL CARE FACILITIES

ITEMS: 6.1.0 through 6.4.0



ITEM 6.1.0 | MEDICAL CARE FACILITIES - GENERAL

Medical care facilities Included in this section are those in which people receive physical or medical treatment or care and where persons may need assistance in responding to an emergency and where the period of stay may exceed twenty -four hours. In addition to the requirements of 4.1 through 4.35, medical care facilities and buildings shall comply with 6.

(1) Hospitals - general purpose hospitals, psychiatric facilities, detoxification facilities - At least 10 percent of patient bedrooms and toilets, and all public use and common use areas are required to be designed and constructed to be accessible.

(2) Hospitals and rehabilitation facilities that specialize in treating conditions that affect mobility, or units within either that specialize in treating conditions that affect mobility - All patient bedrooms and toilets, and all public use and common use areas are required to be designed and constructed to be accessible.

(3) Long term care facilities, nursing homes - At least 50 percent of patient bedrooms and toilets, and all public use and common use areas are required to be designed and constructed to be accessible.

(4) Alterations to patient bedrooms.

(a) When patient bedrooms are being added or altered as part of a planned renovation of an entire wing, a department, or other discrete area of an existing medical facility, a percentage of the patient bedrooms that are being added or altered shall comply with 6.3. The percentage of accessible rooms provided shall be consistent with the percentage of rooms required to be accessible by the applicable requirements of 6.1(1), 6.1(2), or 6.1(3), until the number of accessible patient bedrooms in the facility equals the overall number that would be required if the facility were newly constructed. (For example, if 20 patient bedrooms are being altered in the obstetrics department of a hospital, 2 of the altered rooms must be made accessible. If, within the same hospital, 20 patient bedrooms are being altered in a unit that specializes in treating mobility impairments, all of the altered rooms must be

made accessible.) Where toilet/bath rooms are part of patient bedrooms which are added or altered and required to be accessible, each such patient toilet/bathroom shall comply with 6.4.

(b) When patient bedrooms are being added or altered Individually, and not as part of an alteration of the entire area, the altered patient bedrooms shall comply with 6.3. unless either: a) the number of accessible rooms provided in the department or area containing the altered patient bedroom equals the number of accessible patient bedrooms that would be required if the percentage requirements of 6.1(1). 6.1(2) or 6.1(3) were applied to that department or area: or b) the number of accessible patient bedrooms in the facility equals the overall number that would be required if the facility were newly constructed. Where toilet/bathrooms are part of patient bedrooms which are added or altered and required to be accessible. each such toilet / bathroom shall comply with 6.4.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)



ITEM 6.2.0 | MEDICAL CARE FACILITIES - ENTRANCES

At least one accessible entrance that complies with 4.14 shall be protected from the weather by canopy or roof overhang. Such entrances shall incorporate a passenger loading zone that complies with 4.6.6.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)



ITEM 6.3.0 | MEDICAL CARE FACILITIES - PATIENT BEDROOMS

Provide accessible patient bedrooms in compliance with 4.1 through 4.35. Accessible patient bedrooms shall comply with the following:

- (1) Each bedroom shall have a door that complies with 4.13.

EXCEPTION: Entry doors to acute care hospital bedrooms for in-patients shall be exempted from the requirement in 4.13.6 for maneuvering space at the latch side of the door if the door is at least 44 in (1120 mm) wide.

- (2) Each bedroom shall have adequate space to provide a maneuvering space that complies with 4.2.3. In rooms with 2 beds. It is preferable that this space be located between beds.

- (3) Each bedroom shall have adequate space to provide a minimum clear floor space of 36 in (915 mm) along each side of the bed and to provide an accessible route complying with 4.3.3 to each side of each bed.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)

ITEM 6.4.0 | MEDICAL CARE FACILITIES - PATIENT TOILET ROOMS

Where toilet/bathrooms are provided as a part of a patient bedroom, each patient bedroom that is required to be accessible shall have an accessible toilet/bathroom that compiles with 4.22 or 4.23 and shall be on an accessible route.

(“1991 Standards for Accessible Design”, 28 CFR 36 Appendix D)



APPENDIX



COPYRIGHT NOTICE

TextBookDiscrimination.com is not the author of these guidelines. Instead, TextBookDiscrimination.com merely re-printed and reformatted them for easier use.

ORIGINAL SOURCE

<u>#</u>	<u>Item</u>	<u>Link</u>
1	Original Source	www.ecfr.gov

INTERACTIVE VERSION

<u>#</u>	<u>Item</u>	<u>Link</u>
1	Web	TextBookDiscrimination.com/Handbooks/Access/Buildings/C06

CONTACT INFORMATION

E: TextBookDiscrimination@gmail.com

W: www.TextBookDiscrimination.com

Congratulations! You're now **booked up** on Chapter 6 (*MEDICAL CARE FACILITIES*) of the ADA Accessibility Guidelines for Buildings and Facilities!

